

# UNIT ASSESSMENT CERTIFICATE

Issued by a competent body in explosion safety

## ARTIDOR 20ATEX9999 X

We, ARTIDOR Explosion Safety B.V., Emopad 38, 5663 PB Geldrop, The Netherlands, herewith declare that:

**Apparatus:** Explosion-safe air conditioning split system  
**Type:** AR-052/0711  
**Power supply:** 220 – 240 V AC, 50 Hz  
**Capacity:** 7 kW cooling  
**Quantity:** 1 piece  
**Lot No.:** AS209999

has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to directive 2014/34/EU.

Compliance with the Essential Health and Safety Requirements for group II, category 3G equipment has been assured by compliance with the following harmonized standards:

- EN 60079-0:2018
- EN 60079-7:2015 / A1:2018
- EN 60079-11:2012
- EN 60079-18:2015 / A1:2017
- EN 80079-36:2016
- EN 80079-37:2016

The design and the results of the examination and tests carried out are documented in confidential technical construction file No. AS209999, held at the offices of Artidor Explosion Safety B.V.

If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to the special conditions for safe use as described in this declaration.

The marking of the equipment includes the following:



II 3 G Ex ec h ic mc IIC T3 Gc  
II 3 G Ex ec h ic IIC T4 Gc  
II 3 G Ex ic IIC T6 Gc

Outdoor unit  
Indoor unit  
Remote Control

This certificate only relates to the examination and tests according to directive 2014/34/EU and to the equipment of the above mentioned type, lot number and Ex code.

Production is controlled by the ARTIDOR Quality Assurance system in accordance with ISO 9001:2015 and annex VIII of directive 2014/34/EU.

12. This certificate does not imply that the apparatus meets all statutory requirements in any particular industry or circumstance.
13. The ambient temperature allowed for the apparatus is -20 °C to +52 °C.

14. Description

The air conditioning split system consists of an indoor unit, an outdoor unit and a remote control. In function the system refrigerates air. The indoor unit contains a heat exchanger which is connected to the outdoor unit using special tubing. The outdoor unit provides a continuous flow of cold fluid which decreases the temperature of the heat exchanger, which in its turn absorbs the energy of the air, resulting in a room air temperature decrease. The remote control enables the user to operate the indoor unit.

An ignition hazard assessment in accordance with EN 80079-36 has been carried out to the apparatus. Each part has been assessed with regard to its explosion-safe properties and is modified and marked accordingly.

The outdoor unit consists of a sheet steel enclosure containing the compressor, 4-way valve, expansion valve(s), NTC temperature sensors, fan assembly and the control electronics. The aluminium connection box for connection of the power cable and the interconnecting cable to the indoor unit is mounted at the front of the unit. The sheet steel enclosure is partly part of the protection degree against ignition applied.

The indoor unit consists of an electrically driven fan assembly, electronics PCB and NTC temperature sensors all covered by a non-metallic hood. The surface resistance of the non-metallic hood is higher than  $10^9$  Ohm. A warning is attached to the outside of the hood to draw attention to the risk of electrostatic charge.

The remote control contains electronics (PCB) with a display and membrane pushbuttons all housed in a non-metallic housing containing two (2) 1,5 V DC AAA dry cell batteries.

The apparatus under (4) in its basic version is originally manufactured by Daikin Europe N.V., Oostende, Belgium with the following type identification and serial number(s):

outdoor unit: RZAG71MV and serial No. 6032763xxx  
indoor unit: FAA71A and serial No. 5240072xxx

15. Electrical data:

Supply voltage: 220 - 240 V AC, 50 Hz  
Electrical power: 2,91 kW  
Current rating: 15,2 A  
To be fused at: 20 A max.

16. **Special conditions for safe use**

1. Install an isolating switch close to the apparatus and be sure that it's explosion-safe in accordance with the classification of its environment.
2. Pre-fuse the electric power supply in accordance with the power consumption of the apparatus connected.

Geldrop, 28 April 2020

M. Moolenaar  
Managing Director and EX Authorized Person